

Memo No:- 2037

Date:- 28/09/2026

Subject : Physical / Chemical Examination Report of Water Sample

TC-11875

Sample ID/Classification : HSR/04072/9/2026 / Private	Sample Details	Date & Time
Sender : AAKAR UNIVERSAL SCHOOL	Collected By	DEEPAK
Location : , PARBHUWALA ROAD, UKLANA	Collection Date	24/09/2026 at 11:02
Sample Description : Drinking Water	Received at lab	25/09/2026 at 13:27
Latitude / Longitude : 75.900228 / 29.490626	Analysis Start Date	25/09/2026
	Analysis End Date	28/09/2026
	Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.73	1 NTU	5 NTU	APHA 24th Edition -2130 B : 2023
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	5	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120-B : 2023
5	Total Dissolved Solids @ 180°C ± 2°C	152	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C : 2023
6	Total Hardness as CaCO ₃	108	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C : 2023
7	Calcium (as Ca)	18.11	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B : 2023
8	Magnesium (as Mg)	15.26	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B : 2023
9	Total Alkalinity	48	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B : 2023
10	Chloride (as Cl)	56.72	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B : 2023
11	Sulphate as So ₄	39	200 mg/lit.	400 mg/lit.	APHA 24th -4500 SO ₄ -E : 2023
12	Fluoride (as F)	0.218	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C : 2023
13	Iron (as Fe)	0.01	1.0 mg/lit.	1.0 mg/lit.	USEPA 45(126-43459) : 2018
14	Nitrate (as NO ₃)	1.21	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D : 2023
15	pH @ 25°C	7.26	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B : 2023

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

KANCHAN BISHNOI ,CHEMIST
DISTRICT WATER TESTING LABORATORY,HISAR
email:-chemist.hisar@phedharyana.gov.in